

**SSN**  
ACADEMIC  
BLOCK

# SUSTAINABILITY DESIGN ANALYSIS

**SHIV NADAR**  
UNIVERSITY  
CHENNAI

@ KELAMBAKKAM  
CHENGALPATTU, TAMILNADU  
February 2023



 **TRILOGUE**


WHERE **EARTH** MEETS ECONOMICS




# 1.INTRODUCTION

Passive Design Analysis is performed for Shiv Nadar University, Kelambakkam which falls under warm and humid category under the ECBC 2017.

Simulation Analysis is performed for SNU academic Building with a Built-up Area of 8,753 Sq.m.



Site location



Research Building

Academic Building

Proposed Building






**SSN**

**ACADEMIC  
BLOCK**


# SITE PLAN

## LEGEND :

1. Vehicular drive way
2. Vehicular drop-off
3. Main entrance
4. Pedestrian footpath
5. Services drop-off
6. Internal courtyard seating
7. Existing Storm water drain



# GROUND FLOOR PLAN



LEGEND :

- 1. Verandah
- 2. Entrance lobby
- 3. Admin offices
- 4. Conference room
- 5. Lunch room
- 6. HOD Cabins
- 7. Pantry & Toilets
- 8. Library
- 9. Physics laboratory
- 10. Central Atrium
- 11. Main Staircase
- 12. Passenger lift
- 13. Gents Toilet
- 14. Ladies Toilet
- 15. PWD Toilet
- 16. Staircase
- 17. Cafeteria
- 18. Outdoor Cafeteria
- 19. Service entrance
- 20. Store room

LEGEND :


- 21. Service lift
- 22. Open to Sky Courtyard
- 23. Language laboratory
- 24. Electrical room
- 25. VIP waiting lounge
- 26. Common lounge room



# FIRST FLOOR PLAN

## LEGEND :


1. Double height verandah
2. Student lounge area
3. Sitout terrace
4. Open to Sky courtyard
5. 67 seater Classroom
6. Chemistry Laboratory
7. Staircase
8. Double height lecture theater
9. Gents toilet
10. Ladies toilet
11. PWD Toilet
12. Cut - out to Atrium space
13. Passenger lift
14. Sick room
15. Service lift
16. Electrical room
17. Server room



## SECOND FLOOR PLAN

### LEGEND :


1. Open to Sky courtyard
2. Staircase
3. Faculty cabins
4. 67 seater Classroom
5. Drawing hall
6. Ladies toilet
7. Gents toilet
8. PWD Toilet
9. Passenger lift
10. Open terrace
11. Non teaching Staff room
12. Service lift
13. Cut out to Atrium space
14. Electrical room
15. Server room



# THIRD FLOOR PLAN

LEGEND :


- 1. Open to Sky courtyard
- 2. Staircase
- 3. Faculty cabins
- 4. 67seater Classroom
- 5. Drawing hall
- 6. Ladies toilet
- 7. Gents toilet
- 8. PWD Toilet
- 9. Passenger lift
- 10. Over looking terrace
- 11. CCTV and control room
- 12. Service lift
- 13. Cut out to Atrium space
- 14. Student lounge area
- 15. Electrical room
- 16. Server room



# TERRACE FLOOR PLAN


LEGEND :

- 1. OTS Courtyard
- 2. Staircase
- 3. Open terrace
- 4. Lower terrace
- 5. RO Plant
- 6. OHT
- 7. Skylight courtyard




## 2.SCOPE OF WORK


The following analysis have been performed for SNU project for better building performance and facilitate climate adaptive strategies .  
The analysis is performed using IESVE Tool



# 3.MODEL SNAPSHOTS




Site Model




View from South direction

# 3.MODEL SNAPSHOTS




Site Model




View from West direction

# 3.MODEL SNAPSHOTS




Site Model




View from North direction

# 3.MODEL SNAPSHOTS




Site Model




View from East direction


# 3.MODEL SNAPSHOTS




South Elevation



West Elevation




North Elevation



East Elevation


# 4. CLIMATE ANALYSIS

Max & Min Dry-bulb Temperature; Max wet-bulb Temperature




# Wind Speed [Max- 25.4 m/s @ 17th July 4AM; Min- 0m/s @ 1st Jan 1AM]


Wind speed: (IND\_Chennai\_432790\_ssn 1.epw) - m/s



## Windrose diagram – Annual




- 0 - 3 m/s
- 3 - 6 m/s
- 6 - 9 m/s
- 9 - 12 m/s
- 12 - 15 m/s
- > 15 m/s






The predominant wind direction is from North-East to South -West



## Wind Speed [Max- 25.4 m/s @ 17th July 4AM; Min- 0m/s @ 1st Jan 1AM]



## Windrose diagram – MAY




Hottest Month  
-MAY  
44.2°C  
48.2% RH


The wind direction is from South to North direction



# Wind Speed [Max- 25.4 m/s @ 17th July 4AM; Min- 0m/s @ 1st Jan 1AM]



## Windrose diagram –AUGUST




Most hot-humid month-AUGUST  
 33.5 °C  
 52.4% RH



The wind direction is from North -West to South-East direction



# Wind Speed [Max- 25.4 m/s @ 17th July 4AM; Min- 0m/s @ 1st Jan 1AM]



## Windrose diagram – JANUARY



Coldest Month -  
**JANUARY**  
 31 °C  
 51.7% RH

The wind direction is from North to South




## VENTILATION ANALYSIS

- Ventilation Analysis is performed for Non Airconditioned spaces in Academic Buildings.
- The simulation is performed by considering 50 % Operable windows in all Non-Air-conditioned Areas.
- The Annual air flow rate and peak room temperature is determined from the ventilation Analysis.

Project Name	: Shiv Nadar University
Site Location	: Kelambakkam ,Chennai
Built-up Area	: 8,752 Sq.m
Academic Building AC Area	: 5,546 Sq.m
Key Description	: Educational Facility
Geographical Location	: 12.75° N , 80.20° E
Climate Zone	: Warm & Humid

# RESULTS

The Non-Air conditioned regularly occupied spaces are taken from the analysis



Room Spaces	Air Temperature(Deg C) in degree Celsius for construction options External temperature condition: 41.40degC on May 28 <sup>th</sup> 2024							
	Baseline( Box model)	Red Brick	Fly Ash Brick	AAC Brick	Cavity Wall	EIFS	EIFS With High SRI Paint	AAC Brick Brick With High SRI Paint
ENTRANCE LOBBY	43.54	40.41	40.38	40.34	40.39	40.29	39.88	39.91

Room Spaces	Air change rate(ACH) in degree Celsius for construction options External temperature condition: 41.40degC on May 28 <sup>th</sup> 2024							
	Baseline( Box model)	Red Brick	Fly Ash Brick	AAC Brick	Cavity Wall	EIFS	EIFS With High SRI Paint	AAC Brick Brick With High SRI Paint
ENTRANCE LOBBY	5.36	7.69	7.58	7.38	7.62	7.19	8.96	8.75

# AIR VELOCITY AND ACH AT MARKED POINTS




Space Name	Floor	ACH(Peak Humidity Day)	ACH(Peak Dry Bulb Temperature Day)	ACH(Peak Wind speed Day)	Annual ACH(Mean)
Lobby zone 1	Ground	16.25	17.99	14.04	16.17
Lobby zone 2		10.61	11.30	11.71	11.56
Lobby zone 3		14.51	16.91	15.02	15.72
Open Terrace 4	First	150.93	142.04	145.65	153.57
Lobby zone 5	Second	14.18	11.85	14.50	14.09

# 5. DESIGN RECOMMENDATIONS FOR WARM AND HUMID CLIMATE


## ORIENTATION




Orientation of buildings towards prevailing wind direction for ventilation in summer  
 vegetation for deflecting wind




## SPACING




Well shaded courtyards and open planning with buffer spaces  
 Open spacing for breeze penetration



## OPENING




In north at body height on windward side provide large openings, 40-80% Exclude direct sunlight



## WALLS / ROOFS




Wall: heavy shaded walls to reduce heat gain in summer (west and south)  
 Roof: Material with high SRI for maximum emissivity to minimize heat gain in summer



## AIR MOVEMENT


Cross ventilation through openings creating stack effect

# SOLAR THERMAL ANALYSIS




# SOLAR ANALYSIS -Annual


## Roof Radiant Heat Academic Building



Key plan




Proposed Model






Box Model

01/Jan - 00:00 to 31/Dec - 23:00

kWh/m<sup>2</sup>





# SOLAR ANALYSIS -Annual



Northern Facade Radiant heat(Box Model)




Northern Facade Radiant heat(Proposed Model)



Facade	Baseline Design Solar Radiation(KWH/Sq.m)	Proposed Design Solar Radiation(KWH/Sq.m)	% Reduction In thermal Radiation
North	650	325	50%





# SOLAR ANALYSIS -Annual



Southern Facade Radiant heat(Box Model)




Southern Facade Radiant heat(Proposed Model)



Facade	Baseline Design Solar Radiation(KWH/Sq.m)	Proposed Design Solar Radiation(KWH/Sq.m)	% Reduction In thermal Radiation
South	1000	550	55%





# SOLAR ANALYSIS -Annual



Western Facade Radiant heat(Box Model)



Western Facade Radiant heat(Proposed Model)



Facade	Baseline Design Solar Radiation(KWH/Sq.m)	Proposed Design Solar Radiation(KWH/Sq.m)	% Reduction In thermal Radiation
West	1023	666	65%




# SOLAR ANALYSIS -Annual





01/Jan - 00:00 to 31/Dec - 23:00

kWh/m<sup>2</sup>



Eastern Facade Radiant heat(Box Model)




Eastern Facade Radiant heat(Proposed Model)



Facade	Baseline Design Solar Radiation(KWH/Sq.m)	Proposed Design Solar Radiation(KWH/Sq.m)	% Reduction In thermal Radiation
East	1010	808	80%



## SOLAR THERMAL ANALYSIS INFERENCE




Facade	Baseline Design Solar Radiation(KWH/Sq.m)	Proposed Design Solar Radiation(KWH/Sq.m)	% Reduction In thermal Radiation
North	650	325	50%
South	1000	550	55%
West	1023	666	65%
East	1010	808	80%

- Hot and Dry winds(41 °C and 30% RH) is observed from South and west directions in May, By planting Large foliage trees in Western and southern façade site temperature is substantially reduced.
- Deploying Shading Elements/Large canopy trees shall reduce façade temperature. Thus, Heat ingress through Building Envelope is reduced.
- It is also observed that the Southern ,Eastern and Western façade is exposed to High Radiation .

---

## HVAC ANALYSIS



## HVAC ANALYSIS

- HVAC Analysis is performed for Academic Building.
- The Project has used efficient HVAC system which minimizes HVAC ODP and GWP.
- Implementing Efficient HVAC system shall achieve significant Energy savings.

Project Name	: Shiv Nadar University
Site Location	: Kelambakkam ,Chennai
Built-up Area	: 8,753 Sq.m
Academic Building AC Area	: 5,546 Sq.m
Key Description	: Educational Facility
Geographical Location	: 12.75° N , 80.20° E
Climate Zone	: Warm & Humid


## PARAMETERS CONSIDERED FOR SIMULATION

Parameters	Red Brick (Base Box Model)	Red Brick U Value(W/sq.mk)	Fly Ash Brick U Value(W/sq.mk)	AAC U Value \ (W/sq.mk)	Cavity Wall U Value(W/sq.mk)	EIFS U Value(W/sq.mk)
External Wall(W/sq.m k)	3.28	3.28	2.31	0.98	1.35	0.25
Roof(W/sq.m k)	3.41(Roof - Concrete)	3.41(Roof - Concrete)	0.26(Roof with Rock Wool Insulation)			
SRI ( Solar Reflective Index)	53	53	53	100	53	100
External Window(W/sq.m k)	5.5					
SHGC	0.37					
VLT	0.23					


## PARAMETERS DATA CONSIDERED FOR SIMULATION

Parameters	Base case (Actual) case
Internal Lighting(W/sq.m)	12.92
People load(Sq.m/Person)	15.51
Equipment Load (W/sq.m)	5.38
Primary HVAC System type	Split system system
HVAC Cooling Set point	24°C
Fresh air	As per ASHRAE 62.1 2016
Timing Profile	8AM to 6 PM

# HVAC ANALYSIS SUMMARY-ACADEMIC BUILDING



Box Model



Proposed Model

PARAMETRS	Red Brick (Box Model)	Red Brick	Proposed case(AAC)	Fly ash Brick	Cavity Wall	EIFS	Proposed case(AAC with High SRI)	Proposed case(EIFS with High SRI)
Peak Load(TR)	179	157	145	152	149	140	142	136
HVAC Consumption(M WH)	946	834	781	813	792	770	765	754
Drop in Cooling Capacity (%)	24.02%							
Drop in Cooling Consumption (%)	20.29%							


---

# DAYLIGHTING ANALYSIS




# DAYLIGHT ANALYSIS

## Regularly occupied spaces considered for simulation - Academic Building



First Floor Plan



Regularly occupied spaces

### Regularly occupied First floor Room Spaces



F-CLASSROOM 1

F-CLASSROOM 2

F-CLASSROOM 3

F-CLASSROOM 3

# DAYLIGHT ANALYSIS INFERENCE



**BEST**  
43% VLT\*



**BETTER**  
50% VLT\*



**GOOD**  
69% VLT\*




S.NO	SPACE NAME	BASELINE DAYLIGHT PERCENTAGE(%)	PROPOSED(WITH LIGHT SHELVES) DAYLIGHT PERCENTAGE(%)
1	Class Room 1(North)	46.88	63.21
2	Class Room 2(West)	51.01	69.37
3	Class Room 3(South)	45.91	62.52
4	Class Room 4(South west)	45.7	60.95

# Base case(Without Light shelves) - Academic class room 1 First floor

## Base case

394	1062	1108	1034	1341	936	1298	1166	1003	1126	42
406	548	615	655	701	675	699	653	626	535	39
327	348	392	427	461	448	457	448	399	360	30
257	261	289	324	330	340	336	322	306	267	24
192	206	218	235	228	242	247	233	204	203	19
150	155	154	176	185	158	181	167	173	154	13
120	118	118	137	130	120	138	117	120	118	11
94	91	85	93	93	96	97	94	92	94	82
72	66	67	68	79	75	72	79	69	80	67
57	49	58	56	59	54	59	54	55	51	56
49	41	47	42	44	46	50	45	46	47	50
44	38	38	40	40	43	40	41	40	41	46
34	28	32	37	37	40	41	39	39	39	37
27	26	26	38	46	45	46	45	46	44	44
26	24	24						1119	1348	15
27	23	23						1296	1535	18



Threshold Settings


Value (Lux)   Invert

Threshold > 110.00 Lux = 46.88 % ( 65.91 m²)

# Proposed case(With Light shelves) - Academic class room 1 First floor

## Proposed case

472	1091	1190	1138	1430	1032	1378	1255	1083	1182	52
545	713	816	891	945	894	941	880	838	743	58
458	533	601	654	683	663	678	637	601	510	44
369	402	451	466	487	507	487	476	442	402	36
297	317	340	360	366	379	353	358	325	314	29
241	248	257	267	276	280	277	266	251	251	22
191	194	207	206	224	220	213	214	196	190	18
153	159	156	163	157	168	168	165	161	156	14
127	121	127	128	131	135	133	129	129	114	12
102	96	98	98	109	104	110	109	107	97	10
88	69	88	91	91	87	87	84	84	88	85
73	61	71	75	75	79	71	70	76	74	66
61	55	60	64	75	70	65	74	75	65	65
55	47	48	69	83	80	80	82	81	82	72
48	43	42								1122 1349 15
49	44	43								1305 1523 18





**Threshold Settings** ✕

Value (Lux)   Invert

Threshold > 110.00 Lux = 63.21 % ( 88.86 m<sup>2</sup>)

# Base case(Without Light shelves) - Academic class room 2 First floor

## Base case





Threshold Settings

Value (Lux)   Invert

Threshold > 110.00 Lux = 51.01 % ( 68.72 m<sup>2</sup>)

# Proposed case(With Light shelves) - Academic class room 2 First floor

## Proposed case





Threshold Settings

Value (Lux)   Invert

Threshold > 110.00 Lux = 69.37 % ( 93.46 m<sup>2</sup> )

# Base case(Without Light shelves) - Academic class room 3 First floor

## Base case



Threshold Settings


Value (Lux)   Invert

Threshold > 110.00 Lux = 45.91 % ( 70.23 m<sup>2</sup>)

# Proposed case(With Light shelves) - Academic class room 3 First floor

## Proposed case

7	71	68	72	74	71	77	69	74	73	78
0	64	67	66	65	60	63	69	61	63	67
8	63	65	65	60	68	56	61	70	67	75
1	75	70	69	79	76	67	75	68	74	68
1	80	73	65	84	86	85	82	80	80	90
07	98	98	102	105	97	97	102	101	93	84
28	124	125	129	126	128	127	123	132	131	112
67	139	150	173	177	170	176	162	172	152	158
87	203	198	209	215	223	223	219	195	194	181
55	252	256	276	283	299	283	277	266	233	234
15	316	345	349	357	373	384	376	360	339	305
10	426	438	471	534	528	503	512	482	432	403
12	557	602	681	697	715	715	693	646	597	523
14	765	880	964	1011	1011	999	971	913	834	690
74	1083	1374	1362	1555	1406	1491	1467	1293	1317	864



**Threshold Settings** [Close]


Value (Lux)   Invert

Threshold > 110.00 Lux = 62.52 % ( 95.62 m<sup>2</sup>)

# Base case(Without Light shelves) - Academic class room 4 First floor

## Base case

38	38	41	40	43	49	45	40	40	36
34	33	33	34	33	35	35	35	33	32
33	35	37	33	38	36	32	35	32	34
41	41	35	37	37	38	39	41	36	47
43	40	44	48	41	49	41	44	39	43
54	50	54	51	58	61	60	47	48	56
72	64	70	71	66	74	81	68	62	58
79	100	81	87	95	91	85	95	78	84
112	120	113	114	120	137	131	110	114	102
157	154	151	152	149	171	148	159	152	143
197	199	220	219	230	228	221	219	210	191
243	267	304	319	309	328	315	302	271	251
340	377	406	447	453	456	437	424	390	345
469	555	621	652	682	687	646	641	567	463
706	1050	1017	1247	1173	1132	1225	1034	1071	770



**Threshold Settings** [Close]


Value (Lux)   Invert

Threshold > 110.00 Lux = 45.70 % ( 69.95 m<sup>2</sup>)

# Proposed case(With Light shelves) - Academic class room 4 First floor

## Proposed case

69	70	68	71	74	72	71	68	72	71
57	57	56	58	63	61	69	63	59	67
65	59	64	66	64	67	61	60	62	59
77	76	66	65	63	67	68	60	71	67
82	79	81	85	83	84	78	77	82	77
99	90	99	103	100	102	105	91	91	87
126	110	130	129	123	122	132	117	122	97
152	143	162	170	155	168	158	165	159	145
194	211	211	218	228	226	228	211	193	197
250	254	261	286	262	284	286	259	251	255
308	324	357	385	378	385	388	372	351	328
418	457	498	490	514	523	514	493	447	398
526	603	656	713	730	697	714	663	617	530
710	845	933	987	1046	1027	987	949	852	705
916	1348	1285	1469	1426	1474	1526	1320	1348	996





Threshold Settings

Value (Lux)   Invert


Threshold > 110.00 Lux = 60.95 % ( 93.31 m<sup>2</sup>)

# MATERIAL AND LIFE-CYCLE ANALYSIS




## MATERIAL ANALYSIS


- Material Analysis is done using IESVE Simulation Tool
- Three wall assembly has been taken for the comparative analysis
- The result is compared using U-values from the result generated.



**Project Base case : Brick**  
**Wall U value – 3.28 W/m<sup>2</sup>k**




**Proposed case 1 :Fly ash**  
**Wall U value – 2.32 W/m<sup>2</sup>k**




**Proposed case 2: AAC Block**  
**Wall U value – 0.98 W/m<sup>2</sup>k**

# MATERIAL ANALYSIS



**Proposed case 3 : Cavity wall**  
**Wall U value – 1.35 W/m<sup>2</sup>k**



**Proposed case 4 :EIFS**  
**Wall U value – 0.25 W/m<sup>2</sup>k**

# LIFE-CYCLE ANALYSIS


Address: Shiv Nadar University, Chennai

Author: Earthonomic Engineers Pvt Ltd, Chennai

## The life cycle assessment scope and service life


The material scope in was the same in both baseline and proposed design. The LCA analysis included following building elements

In the assessment following life cycle stages according to EN 15804 (2012) were included:




## LIFE-CYCLE ANALYSIS- Academic Building(Base case)

Materials	Carbon Emission Value	Units
Cement	13.68	tCO2
Chemicals	0.00	tCO2
Concrete	125.05	tCO2
Metals	3.54	tCO2
Bricks	24.35	tCO2
Insulation	113.17	tCO2
Glass	10.09	tCO2
Ceramic & Sanitary	0.00	tCO2
Aggregates	1.28	tCO2
Wood	3.65	tCO2
Misc.	0.00	tCO2
Fossil fuel emmisions (on-site contruction)	4.70	tCO2
<b>TOTAL EMBODIED CARBON in tons of CO2</b>	<b>299.51</b>	
<b>TOTAL EMBODIED CARBON in kgs of CO2</b>	<b>299507.98</b>	
kgCO2 / sqm.	20.69	
TCO2 / sqm.	0.02	



## LIFE-CYCLE ANALYSIS- Academic Building (Designed case)

Materials	Carbon Emission Value	Units
Cement	4.56	tCO2
Chemicals	0.00	tCO2
Concrete	104.50	tCO2
Metals	3.17	tCO2
Bricks	31.71	tCO2
Insulation	113.17	tCO2
Glass	10.09	tCO2
Ceramic & Sanitary	0.00	tCO2
Aggregates	1.28	tCO2
Wood	3.65	tCO2
Misc.	0.00	tCO2
Fossil fuel emmissions (on-site construction)	4.70	tCO2
<b>TOTAL EMBODIED CARBON in tons of CO2</b>	<b>276.83</b>	
<b>TOTAL EMBODIED CARBON in kgs of CO2</b>	<b>276827.66</b>	
kgCO2 / sqm.	19.12	
TCO2 / sqm.	0.02	



## LIFE-CYCLE ANALYSIS- Academic Building (Basecase vs Proposed)

BASELINE CARBON EMISSION (embodied + operational)			PROPOSED CASE CARBON EMISSION (embodied + operational)		
End use	Energy consumption	Units	End use	Energy consumption	Units
Embodied Carbon for 0 year	299,507.98	KgCO <sub>2</sub>	Embodied Carbon for 0 year	276827.66	KgCO <sub>2</sub>
Over all Baseline Consumption	834,000	kWh	Over all Baseline Consumption	754,000	kWh
Emission factor	0.82	KgCO <sub>2</sub> /kWh	Emission factor	0.82	KgCO <sub>2</sub> /kWh
Embodied & Operational Carbon emissions accumulated after 1 year	983,387	KgCO <sub>2</sub>	Embodied & Operational Carbon emissions accumulated after 1 year	895,107	KgCO <sub>2</sub>
Embodied & Operational Carbon emissions accumulated after 5 year	3,718,907	KgCO <sub>2</sub>	Embodied & Operational Carbon emissions accumulated after 5 year	3,370,027	KgCO <sub>2</sub>
Embodied & Operational Carbon emissions accumulated after 10 year	7,138,307	KgCO <sub>2</sub>	Embodied & Operational Carbon emissions accumulated after 10 year	6,461,427	KgCO <sub>2</sub>


The Proposed case's accumulated carbon emission is predicted to be 9.48% lesser than Baseline emission due to selection of efficient Building Envelope and associated ,HVAC savings.

## Ventilation Analysis

### STUDY:

Simulation performed for Non-Airconditioned spaces considering 50% operable area to determine annual air flow and peak room temperature

### INFERENCE:



There is reduction in indoor temperature by 3.63 °C due to EIFS Material, wind flow and cross ventilation combined with SRI paint on facades and trees for shading the façade and cooling the wind.


## SUMMARY

## Solar Analysis


### STUDY:

The impact of solar radiation on different facades through simulation and design recommendations

### INFERENCE:



### Academic Building



West Façade-463 kwh/sqm to 1023 kwh/sqm


Implementing High SRI paint on Roof, Southern and Western façade shall reduce ingress into the Building.

## Daylight Analysis

### STUDY:

The impact of Light Shelves, Window wall ratio (WWR) and glass Visual light transmittance (VLT) on daylight for Academic building through daylight simulation.

### INFERENCE:



- Daylighting is enhanced by use of light shelves.
- Lower VLT of 23 % is recommended in Air-conditioned spaces.
- Non-Air-conditioned spaces should use clear glass of VLT 80%.

# SUMMARY

## LCA

**STUDY:**  
Comparative study of Embodied & operational carbon emission for Base case and proposed building through life cycle stages according to EN 15804 (2012)

**INFERENCE:**


Baseline Embodied & Operational Carbon emissions accumulated after 10 year	7,138,307	KgCO2
Proposed Embodied & Operational Carbon emissions accumulated after 10 year	6,461,427	KgCO2

**The Proposed case's accumulated carbon emission is predicted to be 9.48% lesser than Baseline emission due to selection of efficient Building Envelope and associated ,HVAC savings.**

## HVAC Analysis

**STUDY:**  
HVAC analysis is performed to give accurate HVAC sizing (Tonnage ) for the proposed Building.


**INFERENCE:**




**Proposed EIFS system achieves 24.02% drop in cooling load and 20.29% drop in Energy consumption for Academic Building compared to Box model.**

## Advantages of the proposed design case

Horizontal Bar Chart: Base vs. Designed with Improvement Annotations



- The proposed design case achieved a 65% reduction in thermal radiation, significantly reducing solar heat gain and thereby improving indoor thermal comfort.
- The indoor air temperature was lowered by 5°C, contributing to improved occupant comfort and reduced cooling loads.
- There is a 20% decrease in HVAC energy consumption in the designed case, reflecting enhanced thermal performance and reduced cooling demand due to passive strategies.
- The designed building allows 16% more daylight, improving indoor lighting quality and reducing dependency on artificial lighting.
- A 9% reduction in carbon emissions was achieved, demonstrating the design's contribution to sustainability and lower environmental impact.
- The wall U-value was significantly reduced by 2.3 W/m<sup>2</sup>K, indicating better insulation and thermal resistance in the proposed design case.



---

# MEP SYSTEM – OPERATING COST COMPARISON

## Savings in HVAC Power Consumption :

S. No	Description	Base Case	Proposed Case
1	Total Cooling Capacity (TR)	333.60	277.87
2	Cooling Capacity after applying 75 % diversity	250.20	208.40
3	Average Power Consumption (ikw / TR)	0.80	0.53
4	Operating Hours per Day	8	8
5	No of Days per year	250	250
6	Annual Power Consumption (kWh)	3,97,955	2,20,581
7	<b>Annual Energy Cost (Energy Cost Assumed as ₹ 8 / kWh)</b>	<b>₹ 31,83,636 /-</b>	<b>₹ 17,64,644 /-</b>
	<b>Saving in Annual Power Consumption Cost</b>	<b>₹ 14,18,992 /-</b>	

## Savings in Fresh Air Power Consumption :

S. No	Description	Base Case	Proposed Case
1	Fresh Air Cooling Capacity (TR)	125.91	116.90
2	Cooling Capacity after applying 75 % diversity	94.43	87.68
3	Average Power Consumption (ikw / TR)	0.80	0.53
4	Operating Hours per Day	8	8
5	No of Days per year	250	250
6	Annual Power Consumption (kWh)	1,50,198	92,799
7	Annual Power Consumption due to the fresh air regulation through the CO2 Sensors for all air conditioning rooms. (Applied 30% savings)	-	64,959
8	<b>Annual Energy Cost (Energy Cost Assumed as ₹ 8 / kWh)</b>	<b>₹ 12,01,583 /-</b>	<b>₹ 5,19,674 /-</b>
	<b>Saving in Annual Power Consumption Cost</b>	<b>₹ 6,81,909 /-</b>	

## Savings in Lighting Power Consumption :

S. No	Description	Base Case	Proposed Case
1	Built-up Area (Sq.m)	9,492	9,492
2	Lighting Power Distribution (Watts / Sqm)	10.7	5
3	Total Power Consumption (kW)	101.56	47.46
4	Operating Hours per Day	8	8
5	No of Days per year	250	250
6	Annual Power Consumption (kWh)	2,03,129	94,920
7	<b>Annual Energy Cost (Energy Cost Assumed as ₹ 8 / kWh)</b>	<b>₹ 16,25,030 /-</b>	<b>₹ 7,59,360 /-</b>
	<b>Saving in Annual Power Consumption Cost</b>	<b>₹ 8,65,670 /-</b>	
	<b>Saving in Annual Power Consumption Cost (%)</b>	<b>53 %</b>	

## Savings in Water Supply :

S. No	Description	Base Case	Proposed Case (20% Efficient Fixtures)
<b>A</b>	<b>Savings on Water Demand</b>		
1	Domestic Water Demand per Day (KLD)	28.6	22.8
2	Flush Water Demand per Day (KLD)	20.7	16.56
3	Total Water Demand per Day (KLD)	49.3	39.44
4	Savings in Water Demand per Day (KLD)	9.86	
	<b>Annual Savings in Water Demand (KL)</b>	<b>2470</b>	
	<b>Annual Cost Savings on Water (Assuming ₹ 1,000 /- per 12,000 Litres Tanker)</b>	<b>₹ 2,05,417 /-</b>	
<b>B</b>	<b>Savings on Sewage treatment</b>		
1	Sewage Generation per day in KLD at 85%	41.91	33.52
2	Savings in Water Demand per Day (KLD)	8.38	
	<b>Annual Savings in Treatment (KL)</b>	<b>2095</b>	
	<b>Annual Treatment Cost savings INR</b>	<b>₹ 6,28,575 /-</b>	
<b>C</b>	<b>Domestic, Flush and Water Treatment plant pump power Saving</b>		
1	Pump Power Consumption (kW)	1.85	1.29
2	Annual Power Consumption kWh (Domestic Water Pump & Flush Water = 4 hours x 250 days) (Filter feeder Pump = 8 hours x 250 days)	2,400	1,660
	<b>Annual Energy Cost (Energy Cost Assumed as ₹ 8 / kWh)</b>	<b>₹ 19,200 /-</b>	<b>₹ 13,280 /-</b>
	<b>Saving in Annual Power Consumption Cost</b>	<b>₹ 5,920 /-</b>	


---

# MEP SYSTEM – ANNUAL POWER CONSUMPTION

## MEP System – Annual Power Consumption

S. No	Description	Base Case	Proposed Case
1	HVAC Annual Power Consumption (kWh)	3,97,955	2,20,581
2	Fresh Air Annual Power Consumption (kWh)	1,50,198	64,959
3	Electrical Annual Power Consumption (kWh)	2,03,129	94,920
4	PHE Annual Power Consumption Pump(kWh)	2,400	1,660
	<b>Total Annual Power Consumption (kWh)</b>	<b>7,53,681</b>	<b>3,82,120</b>
	<b>Reduction in power consumption</b>	<b>49.30 %</b>	

Annual Power Consumption



---

# MEP SYSTEM – RETURN OF INVESTMENT (ROI) ANALYSIS

## Return of Investment (ROI) Analysis

S. No	Description	Amount
1	Increase in Capital Investment (Civil and MEP System)	₹ 2,07,29,258 /-
2	Savings in Operating Cost	
A	Savings in HVAC System	₹ 14,18,992 /-
B	Savings in Fresh Air Load (With CO <sub>2</sub> Sensors Control)	₹ 6,81,909 /-
C	Savings in Lighting Power Consumption	₹ 8,65,670 /-
D	Savings in Water Consumption	₹ 8,33,992 /-
E	Savings in Water Power Consumption	₹ 5,920 /-
	<b>Total Savings in Operating Cost</b>	<b>₹ 38,06,483 /-</b>
	<b>Return of Investment (in Years)</b>	<b>5.45 Years</b>

**Note :** There are onsite and offsite renewable energy are available in our project. Hence, the operation cost savings will be more and ROI will further reduce and more attractive.

---

**THANK YOU**